WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49775
Permit No.
Basin 084

NOTICE OF INTENT NO. 31870

1. OWNER Forrest & Judy Johnson
MAILING ADDRESS 4855 Jackrabbit
Reno, Nevada 89510

ADDRESS AT WELL LOCATION 4855 Jackrabbit
Reno, Nevada 89510

2. LOCATION NW ¼ ~~NE~~SW ¼ Sec. 15 T 22 N N/S R 20 East Washoe County
PERMIT NO. (Issued by Water Resources) 076-140-01 (Parcel No.) Palimino Valley Unit 3 (Subdivision Name) 14-2-0-5

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	
Brown Clay		3	15	
Brown Volcanic				
Rock Fractured		15	94	
Greenish Blue				
Volcanic Rock				
Highly Fractured	X	94	177	
T.D. 177				

Date started December 2, 1995
Date completed December 4, 1995

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		2 hours

8. WELL CONSTRUCTION
Depth Drilled 177 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	50 Feet
8-1/2 Inches		50 Feet	177 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	+1	170

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 X 3
From 170 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, Inc (Contractor)
Address 1800 1/2 Frazer Avenue (Contractor)
Sparks, Nevada 89431
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date December 5, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627