

WHITE-DIVISION OF WATER RESOURCES
 CANARY-CLIENT'S COPY
 PINK-WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

OFFICE USE ONLY
 Log No. 49786
 Permit No. 092A
 Basin 092A

NOTICE OF INTENT NO. 29025

1. OWNER Roxanne Uriarte ADDRESS AT WELL LOCATION Section 3 lot #2. Columbia Hill Road
 MAILING ADDRESS 7675 Rock Creek Way Reno, NV 89506
Sacramento, CA 95824
 2. LOCATION NW 1/4 NE 1/4 Sec. 3 T. 21N N/S R. 18 E. Washoe County
 PERMIT NO. 087-491-03 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	20	20
Quartz & Granite		20	24	4
Brown Clay		24	100	76
D.G.		100	120	20
Brown Clay		120	130	10
D.G.		130	150	20
Brown Clay		150	160	10
D.G.		160	175	15
Brown Clay		175	230	55
Green clay & green shale		230	232	2
Softer-Multi colored rock		232	235	3
(3-5 gpm)				
A little more water	x	235	245	10
(8-10- gpm)				
Brown sand stone		245	250	5
Brown clay		250	265	15
Green shale with multi colored rocks	xx	265	355	90

8. WELL CONSTRUCTION
 Depth Drilled 355 Feet Depth Cased 355 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9 7/8 Inches 0 Feet 355 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	355

Perforations: Type perforation Factory
 Size perforation .060 three row
 From 235 feet to 241 feet
 From 309 feet to 316 feet
 From 348 feet to 355 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 355 feet

9. WATER LEVEL
 Static water level 199 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality not tested

Date started 10-24, 19 95
 Date completed 10-26, 19 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	30		2 hours

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MacKay Pump & Geothermal, Inc. Contractor
 Address 1600 Mt. Rose Hwy. Contractor
Reno, NV 89511
 Nevada contractor's license number 23096
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1719
 Division of Water Resources, the on-site driller:
 Signed R. Bruce MacKay
 By driller performing actual drilling on site or contractor
 Date 10-30-'95