

WHITE—DIVISION OF WATER RESOURCES
 CANARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 49772
 Permit No. _____
 Basin 088

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 29010

1. OWNER Frank Lewis ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5360 Tannerwood same
Reno, NV 89511

2. LOCATION NW 1/4 NE 1/4 Sec 2 T 17N N/S R 19 E Washoe County
 PERMIT NO. 045-552-03
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Multi colored rock with occasional bldrs. Hard		0	82	82
Soft-sands and gravels	X	82	90	8
Hard rock		90	140	50
Soft-sand/gravels	x	140	160	20
Hard rock		160	170	10
Soft-sands/gravels	x	170	201	31
Black granite & quartz with some valcanics		110-	201	

8. WELL CONSTRUCTION
 Depth Drilled 201 Feet Depth Cased 201 Feet

HOLE DIAMETER (BIT SIZE)
 From To
9 7/8 Inches 0 Feet 201 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	201

Perforations:
 Type perforation Factory
 Size perforation .060
 From 141 feet to 151 feet
 From 191 feet to 201 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MacKay Pump & Geothermal, Inc.
 Contractor
 Address 1600 Mt. Rose Hwy
 Contractor
Reno, NV 89511
 Nevada contractor's license number 23096
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
 Signed R. Bruce Mackay
 By driller performing actual drilling on site or contractor
 Date 10-20-'95

Date started 10-10 1995
 Date completed 10-11 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	30+	-	2 hrs.
Pump	25	13	2 hrs.