Washoe Co. Health Permit #5526

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49793
Permit No.
Basin [redacted]

NOTICE OF INTENT NO. 29019

1. OWNER Donna Reese
MAILING ADDRESS 1815 King In Reno 89511

ADDRESS AT WELL LOCATION same

2. LOCATION SE ¼ SE ~~SW~~ ¼ Sec. 27 T. 18 N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 017-055-22 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
We abandoned this 6 5/8" well that was 177' deep by first perforating the well at one foot intervals with four perforations and doing so from 177' to 40' where we hit the cement seal. Static water level was 82'. We filled the well using neat cement with about 2 yards of cement. We cut the casing off below grade.				

Date started Oct. 13, 19 95
Date completed Oct. 13, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 177 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188		

Perforations:
Type perforation Mills Knife
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 82 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MacKay Pump & Geothermal, Inc. (Contractor)
Address 1600 Mt. Rose Hwy. (Contractor)
Reno, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor

Date 10-16-'95

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627