WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49795
Permit No.
Basin 082

NOTICE OF INTENT NO. 17279

1. OWNER John C. Crean
MAILING ADDRESS O'Kain & Joy, Suite 580
18400 Von Karman Ave, Irvine, CA 92715

ADDRESS AT WELL LOCATION Big Bend Ranch
State Route 427 & I-80
Wadsworth, Nevada

2. LOCATION NE ¼ NE ¼ Sec. 4 T. 20 N/S R. 24 E. Storey County
PERMIT NO. M10-776-A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG BB-2

Material	Water Strata	From	To	Thickness
Brown gravelly sand w/silt		0	5	5
Brown silty sand w/minor gravel, clay		5	10.5	5.5
Cobbles-sandy gravel		10.5	15	4.5

Abandonment Procedures: Drilled out blank casing and well screen to 15 feet bgs. Pump grouted neat cement from bottom to surface and finished to grade

RECEIVED
SEP 20 AM 11:27
STATE ENGINEER'S OFFICE

Date started 7/31, 1995
Date completed 7/31, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	15 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	Sched 40	.5	15

Perforations:
Type perforation slotted
Size perforation .020 inch
From 5 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 15
Placement Method: ☒ Pumped ~~☐ Poured~~
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From ~~5~~ feet to ~~15~~ feet

9. WATER LEVEL
Static water level 6.5 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Exploration Drilling (Contractor)
Address 1635 Belford Road (Contractor)
Reno, NV 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8/22/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627