WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41798
Permit No.
Basin 04

NOTICE OF INTENT NO. 31164

1. OWNER JOHN ELLIS
MAILING ADDRESS 1996 Griswold Av
Elko, NV 89801

ADDRESS AT WELL LOCATION Spring Creek

2. LOCATION SE ¼ SE ¼ Sec. 15 T. 33 N/S R. 56 E. Elko County
PERMIT NO. (Issued by Water Resources) 6-30C-16-8 (Parcel No.) Tract of land (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy clay		0	42	42
Cemented aggregate		42	45	3
Green sandy clay		45	130	85
Brown clay		130	153	23
Cemented aggregate		153	157	4
Sand & fine gravel	X	157	195	38

Date started December 15, 19 95
Date completed December 20, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
blowtest	50		3

8. WELL CONSTRUCTION
Depth Drilled 195 Feet Depth Cased 195 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	195 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1 1/2	195

Perforations:
Type perforation millslot
Size perforation 3/16 x 3
From 175 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 195 feet

9. WATER LEVEL
Static water level 124 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed John C Bin (By driller performing actual drilling on site or contractor)
Date 12-20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627