WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49800
Permit No.
Basin 071

NOTICE OF INTENT NO. 32391

1. OWNER Earl Jones
MAILING ADDRESS P.O. Box 1254 Winnemucca, NV 89446
ADDRESS AT WELL LOCATION 1040 E. National Ave Parcel B

2. LOCATION NW ¼ ¼ Sec 20 T 36 N/S R 38 E Humboldt County
PERMIT NO. Issued by Water Resources | 15-191-01 Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Large rocks		0	20	20
Clay		20	30	10
Large gravel		30	50	20
Clay		50	60	10
Large gravel		60	80	20
* Boulders or hard layer				
River sediment		80	120	40
Red Clay		120	140	20
Sand/gravel	XX	140	165	25

* Around 70-100 feet small amounts of water. Client does not want river water so went deeper to next water stratas

Date started 12-4, 1995
Date completed 12-6, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
45	N/A	2½ hr

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 165 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/8	12	188	0	165

Perforations:
Type perforation Factory Cuts
Size perforation 5/32
From 140 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 165 feet

9. WATER LEVEL
Static water level 88 feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Contractor
Address 10700 Grass Vly Contractor Winnemucca, NV
Nevada contractor's license number issued by the State Contractor's Board 0021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed By driller performing actual drilling on site or contractor
Date 12-12-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627