WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49808
Permit No.
Basin 049

NOTICE OF INTENT NO. 30785

1. OWNER FERNANDO MENDIVE
MAILING ADDRESS 1058 Panorama Drive
Elko, NV 89801

ADDRESS AT WELL LOCATION NE corner of 12th Street and Chinook Ave.

2. LOCATION NW ¼ NE ¼ Sec. 33 T. 35 N/S R. 55 E. Elko County

PERMIT NO. | Issued by Water Resources | 37-002-05 Parcel No. | MVR #5 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown clay		2	6	4
Boulders & gravel		6	30	24
Siltstone brown	x	30	200	170
**********				
Siltstone some				
pea gravel	x	200	480	280

RECEIVED 95 DEC 26 PM 2:43 STATE ENGINEER'S OFFICE

Date started November 17, 19 95
Date completed November 20, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
27		3

8. WELL CONSTRUCTION
Depth Drilled 480 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches	0 Feet	480 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+1-1/2	480

Perforations:
Type perforation Mill slot
Size perforation 3/16 x 3
From 200 feet to 220 feet
From 460 feet to 480 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 480 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed Daniel Nelson
By driller performing actual drilling on site or contractor

Date 12-1-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627