WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49811
Permit No.
Basin 048

NOTICE OF INTENT NO. 31170

1. OWNER VICKI CARTER
MAILING ADDRESS 755 Washington
Elko, NV 89801

ADDRESS AT WELL LOCATION SW corner at Pershing & 8th st

2. LOCATION SW ¼ SW ¼ Sec. 15 T. 32 N/S R. 55 E. Elko County
PERMIT NO. (Issued by Water Resources) 27-028-01 (Parcel No.) Lucky Nugget #1 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	6	6
Sandy clay		6	19	13
Sand & gravel		19	35	16
Sandy clay & pea gravel		35	70	35
Blue grey clay		70	180	110
Blrown clay & pea gravel		180	220	40
Dark gray shale-like siltstone	X	220	430	210
Hard grey rock w/ white veins & fractures	X	430	460	30

Date started December 13, 19 95
Date completed December 15, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
blowtest	20		3

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	460 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	460

Perforations:
Type perforation mill slot
Size perforation 3/16" x 3"
From 220 feet to 240 feet
From 440 feet to 460 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 460 feet

9. WATER LEVEL
Static water level 127 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 85 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed (By driller performing actual drilling on site or contractor)
Date 12-20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627