

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 542.010 and NAC 624.340

NOTICE OF INTENT NO. 32114

1. OWNER Ralph Allen ADDRESS AT WELL LOCATION 4 miles south of Elburz exit on I-80  
 MAILING ADDRESS 192-11 Elburz Elko, NV 89801

2. LOCATION SE 12 T 35 R 57 E Elko  
 PERMIT NO. 06-540-13-2 Tract of land  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Clay		2	4	2
Sand & gravel	x	4	22	18
Blue grey shale & clay		22	35	13
Placed 2' chip 3/8 bentonite seal above gravel pack				
Discussed less than 50' seal with Tom Gallagher on 11-13-95				

8. WELL CONSTRUCTION  
 Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 35 Feet  
10-5/8 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+2	35

Perforations:  
 Type perforation Mill slot  
 Size perforation 3/16 x 3" x 6 row  
 From 15 feet to 35 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 13  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 15 feet to 35 feet

9. WATER LEVEL  
 Static water level 5' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality \_\_\_\_\_

Date started November 15 19 95  
 Date completed November 15 19 95

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
blow test	15		1-1/2 hrs

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name HACKWORTH DRILLING, INC. Contractor  
 Address P.O. Box 850 Contractor  
Elko, NV 89803  
 Nevada contractor's license number 020582  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1654  
 Division of Water Resources, the on-site driller  
 Signed John C. Smith  
 By driller performing actual drilling on site or contractor  
 Date 12-4-95