

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24571

1. OWNER Bob BedecARRAX ADDRESS AT WELL LOCATION 330
 MAILING ADDRESS 7595 YORKSHIRE AP #80-300 29
RENO N.V. 89506 ON PATRICIAN DR. & MEAD LANE
 2. LOCATION NW 1/4 SE 1/4 Sec 34 T. 21 N/S R 19 E WASHOE County
 PERMIT NO. 005552 Parcel No. 55 Subdivision Name LEMON VALLEY

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness	
Brown overburden		0	3	3	
Brown D.G.		3	85	82	
GRAY GRANITE		85	215	130	
Brown D.G.		215	219	4	
BLACK + white Perm. T		219	265	46	
		36	219	255	36

8. WELL CONSTRUCTION
 Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 265 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>16</u>	<u>1 5/8</u>	<u>7</u>	<u>265</u>

Perforations:
 Type perforation SLOT
 Size perforation 1/2" x 2"
 From 215 feet to 255 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 60' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 60' feet to 265 feet

Date started 11-27-95 19____
 Date completed 11-30-95 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>3 HR</u>

9. WATER LEVEL
 Static water level 1.53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 52 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name S.M. Drilling Contractor
 Address 1859 Hymers Ave Contractor
SPARKS N.V. 89431
 Nevada contractor's license number 41172
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1940
 Division of Water Resources, the on-site driller.
 Signed David E. Clark
 By driller performing actual drilling on site or contractor
 Date 12-28-95