WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49844
Permit No.
Basin 071

NOTICE OF INTENT NO. 32394

1. OWNER Gerald H. Kelley
MAILING ADDRESS P.O. Box 1705
Winnemucca, NV 89445
ADDRESS AT WELL LOCATION 15600 Grass Valley Rd

2. LOCATION SE ¼ ¼ Sec. 29 T. 34 N/S R. 38 E. Pershing County
PERMIT NO. Issued by Water Resources | 9-250-19 Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND / gravel		0	10	10
SMALL gravel		10	20	10
Large rocks		20	30	10
gravel		30	40	10
gravel		40	50	10
SAND / gravel		50	70	20
rock		70	80	10
gravel		80	100	20
clay		100	110	10
gravel / SAND		110	120	10
B- gravel		120	140	20
in & out of swelling clay		140	175	35
clay / gravel		175	185	10
clay - 20% - gravel 80%		185	205	20
B - gravel		205	240	35
A - gravel		240	270	30
A - gravel -		270	285	15
Brought down viscosity				
Rate of penetration XX		285	320	35
picked up -				

RECEIVED 95 DEC 19 AM 10:38 WATER RESOURCES OFFICE

Date started 12-11, 19 95
Date completed 12-15, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	N/A	7 hr -

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	320

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	188		

Perforations:
Type perforation Factory Cuts
Size perforation 3/32
From 285 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 57
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 57 feet to 320 feet

9. WATER LEVEL
Static water level 265 feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name FRED ANDERSON Contractor
Address 10760 Grass Valley Rd. Contractor
Winnemucca, NV
Nevada contractor's license number issued by the State Contractor's Board 0021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed
By driller performing actual drilling on site or contractor
Date 12-18-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627