

OFFICE USE ONLY  
 Log No. 49845  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20820

1. OWNER Bob Koontz ADDRESS AT WELL LOCATION 1987 WIKO ct. Gardnerville NV 89410  
 MAILING ADDRESS 1987 Cortez Gard NV 89410

2. LOCATION SE 1/4 NW 1/4 Sec. 7 T. 12 N/S R. 21 E Douglas County  
 PERMIT NO. 23-234-08 Parcel No. \_\_\_\_\_ Subdivision Name SageWood

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Rock</u>		<u>0</u>	<u>30</u>	
<u>Rock Sand</u>		<u>30</u>	<u>70</u>	
<u>Rock Clay</u>		<u>70</u>	<u>110</u>	
<u>clay</u>	<u>X</u>	<u>110</u>	<u>182</u>	
<u>Rock, sand &amp; clay</u>	<u>X</u>	<u>182</u>	<u>330</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 330 Feet Depth Cased 330 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 1/2 Inches To 0 Feet 330 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>7</u>	<u>.688</u>	<u>0</u>	<u>330</u>

Perforations:  
 Type perforation Factory  
 Size perforation 3 3/32  
 From 290 feet to 320 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 Ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 330 feet

9. WATER LEVEL  
 Static water level 205 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 10/15 19 95  
 Date completed 10/21 19 95

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>760</u>		<u>3 hours</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kawchack Drilling Contractor  
 Address Po Box 359 Minden NV 89423 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board: 021268  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1380+  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10/21/95