DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 49817
Permit No.
Basin
NOI 22246

1. OWNER Brad Page ADDRESS 251 - W River St
Elko NV 89801

2. LOCATION NE ¼ NE ¼ Sec. 9 T. 35 N/S R. 56 E. Elko County
PERMIT NO. SITE LOCATION BLK 38 LOT 2 MVR #3

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2'	2'
Small gravel		2'	160'	158'
gravel	X	160'	178'	18'
clay		178'	181'	3'
gravel	X	181	190'	9'
clay		190	193'	3'
gravel	X	193	260	67'
clay		260	262	2'
gravel	X	262	288	26'
clay		288	291	3'

RECEIVED
95 OCT 20 AM 10:54
STATE ENGINEERS OFFICE

Date started Oct 5th, 19 95
Date completed Oct 11th, 19 95

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 30 Draw down 30 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 9 7/8 inches Total depth 291 feet
Casing record 6"
Weight per foot Thickness .188

Diameter		From		To	
6"	inches	0	feet	291	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 54' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 54' feet to 291' feet

Perforations:
Type perforation Mill Slot
Size perforation 1/8
From 245' feet to 285' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 120' Feet below land surface
Flow G.P.M.
Water temperature 50 ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
AAA
Name David Wages Drilling
Address Box 5596
Nevada contractor's license number 0020684
Nevada driller's license number 1914
Signed David Wages
Date 10-13-95

USE ADDITIONAL SHEETS IF NECESSARY

5471