

OFFICE USE ONLY  
 Log No. 49857  
 Permit No. \_\_\_\_\_  
 Basin 071

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28076

1. OWNER Cliff Burns ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2008 3rd St. Sparks, NV 89431 Lot 9-BIKE 5670 Dove  
 2. LOCATION NE 1/4 Sec. 7 T. 34 S. R. 38 E. Dershing County  
 PERMIT NO. 09433-09 Parcel No. \_\_\_\_\_ Subdivision Name Burns Acres  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Clay/SAND</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>SAND/gravel</u>		<u>20</u>	<u>30</u>	<u>10</u>
<u>Fingered layers</u>		<u>30</u>	<u>100</u>	<u>30</u>
<u>SAND/gravel</u>		<u>100</u>	<u>80</u>	<u>20</u>
<u>SAND/gravel</u>	<u>X</u>	<u>80</u>	<u>110</u>	<u>30</u>

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 110 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 110 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>12</u>	<u>1.88</u>	<u>0</u>	<u>110</u>

Perforations: Factory Cuts  
 Type perforation \_\_\_\_\_  
 Size perforation 2 3/8  
 From 90 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 110 feet

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED Anderson Contractor  
 Address 10760 GRASS VLn Winnemucca, NV Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 11-30-95

Date started 11-28, 1995  
 Date completed 11-29, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>N/A</u>	<u>1 hr.</u>

RECEIVED  
 95 DEC -4 PM 2:10  
 STATE ENGINEERS OFFICE