

OFFICE USE ONLY
 Log No. 49864
 Permit No. 47
 Basin 47

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31152

1. OWNER JERRY RICCI ADDRESS AT WELL LOCATION 1750 Celtic Drive
 MAILING ADDRESS P.O. Box 2579
Elko, NV 89803

2. LOCATION SE 1/4 NW 1/4 Sec 17 T. 34 N/S R. 55 E. Elko County
 PERMIT NO. 06-09F-45-9 Special lands Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Firm brown siltstone		3	18	15
Hard brown siltstone		18	22	4
Soft layer brown siltstone		22	23	1
Firm brown siltstone		24	175	151
Hard brown siltstone		175	180	5
Firm to soft brown siltstone		180	260	80
Hard siltstone		260	320	60
Hard rock layer quartz mix		320	325	5
Firm siltstone & pea gravel mix	X	325	330	5
Hard gravel mix layer		330	340	10
Firm brown siltstone		340	350	10

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)
 From 10-5/8 Inches To 0 Feet 350 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	350	+1

Perforations:
 Type perforation Mill slot
 Size perforation 3/16 x 3
 From 350 feet to 350 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 350 feet to 50 feet

9. WATER LEVEL
 Static water level 260 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature C °F Quality _____

Date started November 3, 1995
 Date completed November 4, 1995

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3.5

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998

Signed Bradley D. Wiese
 By driller performing actual drilling on site or contractor
 Date 11-17-95