LOT 6

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49876
Permit No.
Basin 48

NOTICE OF INTENT NO. 31142

1. OWNER Pinion Homes
MAILING ADDRESS P.O. Box 6001
Elko, NV 89802

ADDRESS AT WELL LOCATION Spring Creek near Trap and Skeet club

2. LOCATION SW ¼ SE ¼ Sec 23 T 33 N/S R 56 E Elko County
PERMIT NO. (Issued by Water Resources) 79-002-06 (Parcel No.) Ruby Mountain Estates (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Clay		2	18	16
Sand & gravel	X	18	52	34
Clay & pea gravel		52	80	28
Sand & gravel		80	92	12
Course gravel & sand		92	120	28

Date started October 31, 19 95
Date completed November 1, 19 95

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Blow test	60		2-1/2 hours

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10-5/8 Inches		0 Feet	120 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13	.188	+1-1/2	120

Perforations:
Type perforation Millslot
Size perforation 3/16 x 3 x 6 row
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [X] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 55 feet to 120 feet

9. WATER LEVEL
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1998
Signed Bradley D. Wright (By driller performing actual drilling on site or contractor)
Date 11-10-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627