

OFFICE USE ONLY  
 Log No. 49881  
 Permit No. \_\_\_\_\_  
 Basin. 48

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30653

1. OWNER SHARON F BERRY ADDRESS AT WELL LOCATION Lot 11 Blk B  
 MAILING ADDRESS Box 265  
Wright way 82732  
 2. LOCATION S.E. 1/4 SW 1/4 Sec 23 T 33 N/S R. 56 E ELKO County  
 PERMIT NO. 79-002-11-9 Parcel No. Ruby MT Subdivision Name ESTATES  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY Loam		0	28	28
Gravel		28	29	1
Clay		29	40	11
Gravel	X	40	45	5
Clay		45	75	30
Gravel		75	76	1
SANDstone	X	76	89	13
Clay		89	102	13
Loose SAND		102	126	24

8. WELL CONSTRUCTION  
 Depth Drilled 126 Feet Depth Cased 126 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 126 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>1.88</u>	<u>72</u>	<u>126</u>

 Perforations:  
 Type perforation slots  
 Size perforation 3/16 x 3"  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 52 feet to 126 feet

Date started 11-13, 1995  
 Date completed 11-14, 1995

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>38</u>		<u>4.5</u>

9. WATER LEVEL  
 Static water level 33 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fentig Drilling Co Contractor  
 Address PO Box 525 Contractor  
ELKO NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shaulc Judge  
 By driller performing actual drilling on site or contractor  
 Date 11-15-95