WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49888
Permit No.
Basin 179

NOTICE OF INTENT NO. 22970

1. OWNER Gerald E. or Rayola H. Webb
MAILING ADDRESS Hc 32 Box 32205 Ely NV 89301-9707
ADDRESS AT WELL LOCATION 9 W. Pole Line Rd. Crosstimbers Sub

2. LOCATION SE ¼ NE ¼ Sec. 15 T. 17 N/S R. 63 E White Pine County
PERMIT NO. N/A (Issued by Water Resources) | Parcel No. E-581-71 | Subdivision Name Crosstimbers

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	
gravel conglomerate		5	30	
Clay Con.		30	35	
gravel con.		35	45	
Clay		45	48	
gravel con		48	60	
Clay		60	64	
gravel		64	65	
Clay		65	70	
gravel	water	70	70.5	
Clay		70.5	82	
gravel	water	82	85	
Sandy Clay		85	88	
gravel	water	88	89	
Sandy clay		89	92	
gravel	water	92	98	
Sandy clay		98	109	
Clay con		109	115	
gravel	water	115	117	
Sandy Clay		117	120	

RECEIVED 95 OCT 30 PM 2:15 STATE ENGINEERS OFFICE

Date started Sept 15, 1995
Date completed Oct 17, 1995

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	5	1 hr.

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	120 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	120

Perforations:
Type perforation Mill
Size perforation 5/8 x 2.5" x 6 saw
From feet to feet
From 74 feet to 115 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 120 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022864
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Nathan Maynard (By driller performing actual drilling on site or contractor)
Date Oct 20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627