WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. ~~[illegible]~~ 49891
Permit No.
Basin 2057

NOTICE OF INTENT NO. 28872

1. OWNER George Ely
MAILING ADDRESS 854 Bohnet Drive
Fairbanks, Alaska 99712

ADDRESS AT WELL LOCATION Preston, Nevada

2. LOCATION SE ¼ NW ¼ Sec. 12 T 12 N/~~S~~ R 61 E White Pine County
PERMIT NO. ____ Issued by Water Resources | Parcel No. 1 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	45	45
Clay & Gravel		45	50	5
Gravel		50	90	40
Clay & Gravel		90	100	10
Water Bearing Gravel	X	100	115	15
Clay & Gravel		115	145	30
Water Bearing Sand & Gravel	X	145	185	40
Clay & Gravel		185	195	10
Water Bearing Sand & Gravel	X	195	201	6

RECEIVED 95 SEP 15 AM 11:34 STATE ENGINEERS OFFICE

Date started September 5, 19 95
Date completed September 7, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150	101	½

8. WELL CONSTRUCTION
Depth Drilled 201 Feet Depth Cased 201 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	201 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	201

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 6 rows
From 100 feet to 201 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 201 feet

9. WATER LEVEL
Static water level 106 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature warm °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, NV 89301

Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641

Signed Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date September 12, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627