

OFFICE USE ONLY
 Log No. 49895
 Permit No. _____
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37581

1. OWNER MIKE BARNETT ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 525 Mogul Mtn. Drive 432 Camino De Grato
Reno, Nevada 89523 Sparks, Nevada 89436

2. LOCATION NE 1/4 SW 1/4 Sec 24 T. 21N N/S R. 20 E Washoe County
 PERMIT NO. 076-400-65 Spanish Springs
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay some gravels		1	6	5
Brown sandy clay		6	18	12
Decomposed granite		18	21	3
Brown sandy clay		21	69	48
Brown clay with some smaller boulders and gravels		69	111	42
Decomposed granite soft		111	115	4
Brown clay w/decomposed granite mixed		115	189	74
Soft zone	X	189	193	4
Weathered granite		193	212	19
Soft zone	X	212	215	3
Weathered granite		215	236	21
Soft zone	X	236	240	6
Weathered granite		240	250	10

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10</u> Inches	<u>0</u> Feet <u>50</u> Feet
<u>8 5/8</u> Inches	<u>50</u> Feet <u>250</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>250</u>

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 200 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 250 feet

9. WATER LEVEL
 Static water level 165 feet below land surface
 Artesian flow 25 G.P.M. 25 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date November 29, 1995

Date started 11-28-95, 19____
 Date completed 11-29-95, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		