WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49900
Permit No.
Basin 99

NOTICE OF INTENT NO. 27675

1. OWNER James H Mueller
MAILING ADDRESS 300 Appolocon Circle Red Rock
ADDRESS AT WELL LOCATION 300 Appolocon Circle Red Rock

2. LOCATION SE ¼ SW ¼ Sec. 9 T. 23 N/S R. 8 E. Washoe County
PERMIT NO. Issued by Water Resources | Parcel No. 78-221-72 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil, Sandy		0	8	8
Clay, Sandy, Rusty		8	24	16
Sand, brown		24	36	12
Sand, white		36	41	5
Sand, brown		41	63	22
D.G.		63	125	62
Granite		125	230	105
Granite Fractured	✓	230	233	3
Granite		233	290	57
Granite with occasional fractures	✓	290	500	210

Date started 7-3, 1995
Date completed 7-31, 1995

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	—	4
Pumping 175		

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	50 Feet
9.5 Inches	50 Feet	500 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.97	0.188	0	500

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32
From 220 feet to 240 feet
From Staggered feet to 290-500 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 500 feet

9. WATER LEVEL
Static water level 122 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling Contractor
Address 2290 Pioneer Drive Contractor
Reno, Nevada 89509
Nevada contractor's license number issued by the State Contractor's Board ~~[illegible]~~ 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed [signature]
By driller performing actual drilling on site or contractor
Date 9/17/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627