WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4469
Permit No.
Basin 107

NOTICE OF INTENT NO. 7112

1. OWNER Joe Accian
MAILING ADDRESS 349 Artist View Wellington Nev. 89444
ADDRESS AT WELL LOCATION 50 Accian Rd. Smith Nev. 89430

2. LOCATION SW ¼ NE ¼ Sec. 21 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. — (Issued by Water Resources) 09-111-11 (Parcel No.) Accian County Estates (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy loam + pea gravel top soil		0	10	10
sandy clay		10	64	54
fine sand	✓	64	87	23
blue clay		87	108	21
brown sandy clay		108	164	56
gravel + coarse sand	✓	164	178	14
sandy clay		178	196	28
mix gravel + coarse sand		196	230	34

Date started May 13, 1995
Date completed May 23, 1995

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	0	3 hrs

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
6 Inches	50 Feet	230 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	230

Perforations:
Type perforation factory saw slott
Size perforation 3/32 x 3
From 200 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From — feet to — feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller (Contractor)
Address P.O. Box 92 Smith Nev. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller
By driller performing actual drilling on site or contractor
Date May 19 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627