WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4914
Permit No. [redacted]
Basin [redacted]

NOTICE OF INTENT NO. 26767

1. OWNER Randy Wishart
MAILING ADDRESS 131 Elizabeth Lane
Dayton NV
ADDRESS AT WELL LOCATION 131 Elizabeth Lane

2. LOCATION SE ¼ SE ¼ Sec. 20 T. 17 N/S R. 22 E. [redacted] County
PERMIT NO. NA (Issued by Water Resources) 03-316-26 (Parcel No.) Mark Twain (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders Gravel Cemented Sand		0	58	58'
Black Broken Shale Rock		58	116'	58'
Brown Clay And Shale		116	198'	82'
Hard Black dense Shale		198	239'	41'
Crevised Black Shale Hard	✓	239	254	15'

RECEIVED 95 AUG 31 AM 11:16 STATE ENGINEERS OFFICE

Date started 8/17/95, 19..
Date completed 8/19/95, 19..

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-17	gpm	3 hrs

8. WELL CONSTRUCTION
Depth Drilled 254 Feet Depth Cased 255' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	70' Feet
8 3/4 Inches		70 Feet	254' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.	1.88	+1	254

Perforations:
Type perforation 3/8 x 6" x 8# Louvered perf
Size perforation Factory Cut
From 234 feet to 254 feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 52'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 52' feet to 254' feet

9. WATER LEVEL
Static water level + 185' feet below land surface
Artesian flow ... G.P.M. ... P.S.I.
Water temperature C °F Quality Good (Clear)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lear Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
S.S. NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8/22/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627