X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49915
Permit No.
Basin 102

NOTICE OF INTENT NO. 259777

1. OWNER Merlin & Carrol Bonds
MAILING ADDRESS 10175 Bass St. Silver Springs NV 89429
ADDRESS AT WELL LOCATION 10175 Bass St. Silver Springs NV

2. LOCATION SE ¼ NE ¼ Sec. 31 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. Ap. 28555, 9838 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	48	48
Tan Clay		48	66	18
Cemented Sands And Gravels	✓	66	91	25
Tan Clay		91	126	35
Sand and Gravel	✓	126	223	97
Gouse Gravel with Some Fine Sand	✓	223	290	67
Gray Clay		290	304	14

JUN -6 A11:06
RECEIVED
STATE ENGINEERS OFFICE
95

Date started 5-20, 1995
Date completed 5-20, 1995

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 7 Hours And produced about 1000 Gallons A Min			
Pumed 850 GPM. With 23' feet Draw Down, 3 Hours.			

8. WELL CONSTRUCTION
Depth Drilled 304 Feet Depth Cased 303 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
17 5/8 Inches	0 Feet	60 Feet
14 3/4 Inches	60 Feet	304 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	33.00	3/8	+1	303

Perforations:
Type perforation mill cut
Size perforation 1/4 x 3 Long 10 Rows
From 100 feet to 304 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-100
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 304 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Merky

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address Po Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031891
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1827
Signed [signature] By driller performing actual drilling on site or contractor
Date 5-23-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627