X

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49916
Permit No.
Basin 179

NOTICE OF INTENT NO. 22968

1. OWNER David Morgan
MAILING ADDRESS P.Box 150508 East Ely NN. 89315
ADDRESS AT WELL LOCATION 283 N. 35 W. Crosstimbers Sub. Lot 51

2. LOCATION NE ¼ SW ¼ Sec. 15 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) | 05-571-17 (Parcel No.) | Crosstimbers Sub. (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	
gravel conglomerate		3	13	
Sandy Clay		13	19	
gravel Con.		19	30	
Sandy Clay		30	40	
gravel clay con.		40	45	
Clay con.		45	48	
gravel con		48	51	
clay con.		51	53	
gravel con		53	54	
clay		54	56	
gravel		56	60	
Sandy Clay		60	85	
gravel	water	85	87	
Sandy Clay		87	105	
gravel	water	105	113	
Sandy Clay		113	128	
gravel	water	128	131	
Sandy Clay		131	136	
gravel con	water	136	139	
Sandy clay		139	148	
gravel Hard	water	148	162	
Clay		162	165	

Date started July 31, 1995
Date completed Aug 14, 1995

RECEIVED
AUG 31 AM 11:15
STATE ENGINEER'S OFFICE

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	5	1 hr

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	80 Feet
8 Inches	80 Feet	165 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	165

Perforations:
Type perforation mill
Size perforation 8 x 2.5 x 6 rows
From feet to feet
From 75 feet to 125 feet
From 145 feet to 165 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 80
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 80 feet to 165 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address P.O. Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orvon Maynard (By driller performing actual drilling on site or contractor)
Date Aug 18-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627