

OFFICE USE ONLY  
 Log No. 29919  
 Permit No. 101  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27016

1. OWNER tina wood ADDRESS AT WELL LOCATION 4989 Cody  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 NW 1/4 Sec. 22 T. 18 N/S R. 28 E. Churchill County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. 006-435-10 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material               | Water Strata | From      | To        | Thick-ness |
|------------------------|--------------|-----------|-----------|------------|
| <u>Sand</u>            | <u>-</u>     | <u>0</u>  | <u>9</u>  | <u>9</u>   |
| <u>Silt</u>            | <u>-</u>     | <u>9</u>  | <u>13</u> | <u>4</u>   |
| <u>Brown Clay</u>      | <u>-</u>     | <u>13</u> | <u>17</u> | <u>4</u>   |
| <u>Brown Sand</u>      | <u>-</u>     | <u>17</u> | <u>36</u> | <u>19</u>  |
| <u>Gray Black Sand</u> | <u>-</u>     | <u>36</u> | <u>64</u> | <u>28</u>  |
| <u>Brown Sand</u>      | <u>-</u>     | <u>64</u> | <u>75</u> | <u>11</u>  |

8. WELL CONSTRUCTION  
 Depth Drilled 75 Feet Depth Cased 75 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 Inches 0 Feet 50 Feet  
6 Inches 50 Feet 75 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>6 5/8</u>       | <u>12.9</u>         | <u>.188</u>             | <u>1</u>    | <u>75</u> |

Perforations:  
 Type perforation Machine slot  
 Size perforation .050  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 67 feet to 73 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 12-4 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Contractor  
 Address Box 888 Contractor  
Fallon  
 Nevada contractor's license number 4752  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772  
 Signed Woolfille  
 By driller performing actual drilling on site or contractor  
 Date June 29-94

Date started June 11 1994  
 Date completed June 11 1994

7. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift |                               |              |
|---|-------------------------------|--------------|
| G.P.M.  | Draw Down (Feet Below Static) | Time (Hours) |
| <u>25</u>   |                               | <u>1</u>     |