WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49938
Permit No.
Basin 087

NOTICE OF INTENT NO. 27310

Consultant:

1. ~~OWNER~~ Advanced Scientific Solutions
MAILING ADDRESS 3983 So. McCarran Blvd. Ste 201
Reno, Nevada 89502

ADDRESS AT WELL LOCATION Karls Silver Club
1029 C Street Sparks, Nevada

2. LOCATION SE ¼ SE ¼ Sec. 5 T. 19N N/S R. 20 E. Washoe County

PERMIT NO. M/O 850 SCMW-1 (Issued by Water Resources) | 032-184-16 (Parcel No.) | Downtown Sparks (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphatic Cement		0	1	1
Fill		1	2	1
Brown to medium grey Silty Gravel: (GM) with sands, cobbles and boulders, Medium dense to very dense, Moist, No odor of Product.		2	20	18
Brown to Medium Grey Silty Gravel: (GM) with sands, cobbles and boulders, Medium dense to very dense, Saturated, no odor of Product.		20	30	10

Date started 10-17-94, 19
Date completed 10-17-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No Test			

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/16 Inches	0 Feet	30 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		40 SCH	0	30
Locking	Christy	Box		

Perforations:
Type perforation Factory Sawed Slot
Size perforation .020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-5
Placement Method: ☒ Pumped ☐ Poured
Bentonite Seal: 5-7
Gravel Packed: ☒ Yes ☐ No Sand Pack filter
From 7 feet to 30 feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 22.2 feet below land surface
Artesian flow NA G.P.M. NA P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
REno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908

Signed Harry C. Hedman (By driller performing actual drilling on site or contractor)
Date April 20, 1995

'95 JUN 5 P3:55 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627