

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21854

Consultant: _____ Client: _____
1. OWNER Steffen Robertson and Kirsten ADDRESS AT WELL LOCATION 2169 Prater Way, Sparks, NV.
MAILING ADDRESS 1755 East Plumb Lane #241 Western Energetix
Reno, Nevada 89502 419 W. Plumb Lane, Reno, Nevada 89509
2. LOCATION DD 1/4 1/4 Sec. 6 T 19N N/S R. 20 E. Washoe County
PERMIT NO. M/O 687 MW-3 032-023-01 Sparks Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other _____ Municipal/Industrial Irrigation Test Stock
4. PROPOSED USE Monitor Air Rotary RVC
5. WELL TYPE Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphaltic Concrete		0	3"	3"
Aggregate Base		3"	1'	9"
Dark Brown Silty Sand (SM), with some gravel and cobbles, non plastic, loose, slightly moist.		1	8	7
Gravels (GP), with brown sand, fine to medium, loose, non-plastic, moist.		8	11	3
Silty Gravels (GM), with considerable sand, fine to medium, loose, non plastic, moist.		11	29.25	18.25
Boulder (granite)		14	15.5	1.5
Boulder (granite)		20	21.5	1.5
Light Brown Silty Gravels (GM), non plastic, loose, wet.		31.25	49	17.75
Considerable cobbles encountered		33	35	2
Color from light brown to rusty brown.				

8. WELL CONSTRUCTION
Depth Drilled 49 Feet Depth Cased 45 Feet
HOLE DIAMETER (BIT SIZE)
From To
9 5/16 Inches 0 Feet 49 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC	Blank	Sch 40	0	20
3/4" PVC		Sch 80	0	48
2" KYA	Sparge		48	49

Perforations: Locking Cap/ Locking Well Protector
Type perforation Factory Sawn Slot
Size perforation .020
From 20 feet to 45 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 15 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Bentonite Seal 15-17 & 45-48
Gravel Packed: Yes No #3 Silica 17-45
From #3 Silica 48-49 feet

9. WATER LEVEL
Static water level n/a feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature n/a °F Quality n/a

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. Contractor
Address P.O. Box 12370 Contractor
Reno, Nevada 89510
Nevada contractor's license number 22549
issued by the State Contractor's Board.
Nevada driller's license number 908 issued by the Division of Water Resources, the on-site driller.
Signed [Signature]
By driller performing actual drilling on site or contractor
Date July 19, 1994

Date started July 28, 1993.
Date completed July 28, 1993.

7. WELL TEST DATA

TEST METHOD	Bailer	Pump	Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no test						