WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 49943
Permit No.
Basin 087

NOTICE OF INTENT NO. 27285

Consultant:
~~1. OWNER~~ Harding Lawson Associates.
MAILING ADDRESS 961 Matley Lane, Suite 110
Reno, Nevada 89501

Client:
ADDRESS AT WELL LOCATION
Nevada Department of Transportation
Pyramid Way Interchange Sparks, Nevada

2. LOCATION NE ¼ NE ¼ Sec. 8 T 19 N/S R 20 E Washoe County
PERMIT NO. M/O 816 MW-2 (Issued by Water Resources) 032-220-71 (Parcel No.) Sparks (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☒ Other Tubex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt Concrete		0	1	1
Brown poorly graded sand with silt, gravel and cobbles; moist.(color change to dark brown-black at 6 feet)	X	1	13	12
Black poorly graded gravel with sand and cobbles; moist		13	21	8
Black Poorly graded sand with gravel and cobbles; moist, wet.		21	25	4
Black poorly graded gravel with sand and cobbles; wet (Becoming brown)	X	25	34	9

Date started 7/21/94, 19
Date completed 7/21/94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No Test		

8. WELL CONSTRUCTION
Depth Drilled 34 Feet Depth Cased 34 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7½ Inches	0 Feet	34 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		SCH 40	0	34
Locking Cap / End Cap				
Steel Well Cover				

Perforations:
Type perforation Factory Sawed Slot
Size perforation .020
From 14 feet to 34 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-9
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Bentonite Seal: 9-11
Gravel Packed: ☒ Yes ☐ No Lonestar #3
From 11 feet to 34 feet

9. WATER LEVEL
Static water level 24.92 8/3/94 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, Nevada 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed Gary R. Hedman (By driller performing actual drilling on site or contractor)
Date April 4, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627