

OFFICE USE ONLY  
 Log No. 49874  
 Permit 83  
 Basin

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

page 1 of 3 pages  
 NOTICE OF INTENT NO. 14915

Consultant:

1. OWNER Kennedy/Jenks, Inc. ADDRESS AT WELL LOCATION Refuse, Inc.  
 MAILING ADDRESS 160 Hubbard Way, Suite #2  
Reno, Nevada 89502 Lockwood landfill Lockwood, NV.  
 2. LOCATION CCAA 1/4 Sec. 22 T. 19N N/S R. 21 E storey County  
 PERMIT NO. M/O-253 LL-2B 04-131-03 Lagomarsino Canyon  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium-Clayey Gravel: at surface, 30-50% Cobbles 4" to 1 foot in size, cobbles consist of andesite & Chert		0	5	5
Poorly Graded Clayey Gravel: 10% fines, prodominantly andesite and silicified tuff fragments.		5	7	2
Lean Clay-Gravel Sand Mixture 95% clay and sand with 5% gravel, clay has medium to high dry strength and medium tou toughness.		7	16	9
Clayey Gravel: Boulders from 16' to 21', Rock clasts are andesite, silicified breccia, tuff breccia, rhyodacite, jasperoid.		16	21	5
Altered Andesite: andesite is blue-gray, feldspars are altered to clay.		21	32	11
Andesite: light gray, 20-30% feldspar phenocrysts in groundmass, feldspars are anhedral, lmm, white 1% pyrite, andesite is slightly silicified.		32	35	2

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/2 Inches To 0 Feet 220 Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6" PVC		SCH 80	0	174.5
End Cap & Lockin Cap				

Perforations:  
 Type perforation Factory Sawn Slot  
 Size perforation .020  
 From 174.5 feet to 213.5 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-166.5'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Bentonite Seal: 166.5-172'  
 Gravel Packed:  Yes  No Lone star #3  
 From 172 feet to 215 feet

9. WATER LEVEL  
 Static water level 82.91 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, Nevada 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908  
 Signed Wayne C. Helman  
 by driller performing actual drilling on site or contractor  
 Date April 6, 1995

Date started 6-27-90, 19\_\_\_\_  
 Date completed 7-2-90, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No Test		

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

page 2 of 3 pages  
 NOTICE OF INTENT NO. 14915

Consultant:

1. OWNER Kennedy/Jenks, Inc. ADDRESS AT WELL LOCATION Refuse, Inc  
 MAILING ADDRESS 160 Hubbard Way, Suite #2  
Reno, Nevada 89502

2. LOCATION 1/4 Sec T N/S R E County \_\_\_\_\_  
 PERMIT NO. M/O-253 LL-2B Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Andesite: light gray, 20-30% feldspar, phenocrysts in felsitic groundmass, feldspars are anhedral, 1mm, white, 1% pyrite, andesite is slightly silicified.		35	70	35
Andesite: very hard, silicified, felsitic groundmass, feldspars are anhedral, 1mm, white, some altered to clay, 3% pyrite, subhedral to anhedral 1mm, disseminated throughout rock.		70	80	10
Andesite: Pyrite is more disseminated through rock, very fine grained.		80	85	5
Andesite: very fine grained pyrite is fresh, medium brown siliceous rock fragments.		85	94	9
Andesite: Increase in Quartz(3%), white, anhedral in aphanitic groundmass, pyrite increases to 5% of rock.		94	115	21
Andesite: small rock fragments, hard, pyrite is irredescent and appears chalcopyrite.				

8. WELL CONSTRUCTION  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, Nevada 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date April 6, 1995

Date started \_\_\_\_\_, 19\_\_\_\_  
 Date completed \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

page 3 of 3 pages  
 NOTICE OF INTENT NO. 14915

Consultant:

1. ~~OWNER~~ Kennedy/Jenks, Inc. ADDRESS AT WELL LOCATION Refuse, Inc  
 MAILING ADDRESS 160 Hubbard Way, Suite #2  
Reno, Nevada 89502

2. LOCATION 1/4 1/4 Sec T N/S R E County \_\_\_\_\_  
 PERMIT NO. M/O-253 LL-2B  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
along fractures. Increase in pyrite in rock. Feldspars altered to clay.		115	125	10
Andesite: has aphanitic groundmass, pyrite is euhedral to anhedral		125	129	4
Andesite: very fine rock fragments, increasing quartz, pyrite is abundant along rock surfaces,		129	145	16
Andesite: medium grained, 5-10% pyrite, disseminated throughout rock, is fine grained and anhedral.		145	160	15
Andesite: 160 170 10		160	170	10
Andesite: Medium grained, 5-10% pyrite, disseminated throughout rock is fine grained and anhedral.		170	178	8
Andesite Breccia:		178	185	7
Andesite:		185	201	16
Andesite: Pyrite is less Disseminated		201	215	14
Andesite: pyrite is clustered, less disseminated, (possibly along fracture planes)		215	220	10

8. WELL CONSTRUCTION  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, Nevada 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908  
 Signed Wayne A. Feldman  
 By driller performing actual drilling on site or contractor  
 Date April 6, 1995

Date started \_\_\_\_\_, 19\_\_\_\_  
 Date completed \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

page one of 4 pages  
 NOTICE OF INTENT NO. 14915

Consultant: \_\_\_\_\_  
 1. ~~OWNER~~ Kennedy/Jenks, Inc. ADDRESS AT WELL LOCATION: \_\_\_\_\_  
 MAILING ADDRESS 160 Hubbard Way, Suite #2 Refuse, Inc.  
Reno, Nevada 89502 Lockwood Landfill Lockwood, NV.  
 2. LOCATION CCAA 1/4 1/4 Sec 22 T. 19N N/S R 21 E Storey County  
 PERMIT NO. M/O-253 LL-2A 04-131-03 Lagmarsino Canyon  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alluvium-Clayey Gravel: at surface, 30-50% cobbles-4" to 1 foot in size, cobbles consist of andesite & Chert.		0	5	5
Poorly Graded Clayey Gravel: 10% fines, prodominantly andesite and silicified tuff fragments.		5	7	2
Lean Clay-Gravel-Sand Mixture: 95% clay and sand with 5% gravel, clay has medium to high dry strength and medium toughness.		7	16	9
Clayey Gravel: Boulders from 16' to 21', rock clasts are andesite, silicified Breccia, tuff breccia, rhyodacite.		16	29	13
Altered Andesite: Andesite is blue-gray, feldspars are altered to clay.		29	32	3
Andesite: light gray, 20-30% feldspar Phenocrysts in groundmass, feldspars are anhedral, 1mm, white, 1% pyrite, andesite is slightly silicified.		32	35	3

8. WELL CONSTRUCTION  
 Depth Drilled 280 Feet Depth Cased 280 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/2 Inches To 0 Feet 280 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		SCH 40	0	40
End Cap				
Locking Cap				

Perforations:  
 Type perforation Factory sawed slot  
 Size perforation .020  
 From 40 feet to 70 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-35'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Bentonite Seal: 35-37'  
 Gravel Packed:  Yes  No Lonestar #3  
 From 37 feet to 71 feet

9. WATER LEVEL  
 Static water level: 37.20 feet below land surface  
 Artesian flow na G.P.M. na P.S.I.  
 Water temperature na °F Quality na

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, Nevada 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908  
 Signed [Signature] by driller performing actual drilling on site or contractor  
 Date April 6, 1995

Date started 6-7-90, 19\_\_\_\_  
 Date completed 6-13-90, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
No Test			

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

page 2 of 4 pages  
 NOTICE OF INTENT NO. 14915

Consultant: \_\_\_\_\_  
 OWNER: Kennedy/Jenks, Inc. ADDRESS AT WELL LOCATION: \_\_\_\_\_  
 MAILING ADDRESS: 160 Hubbard Way, Suite #2  
Reno, Nevada 89502 Refuse Inc.

2. LOCATION: 1/4 Sec T N/S R. E County \_\_\_\_\_  
 PERMIT NO. M/O-253 LL-2A 04-131-03  
 Issued by Water Resources Parcel No. Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Andesite: light gray, 20-30% Feldspar, Phenocrysts in felsitic groundmass, feldspars and anhedral, 1mm, white, 1% pyrite (fresh), Andesite is slightly silicified.		35	39	4
--video-fractures apparent in borehole walls--from 38' to 58'		39	60	21
Video:cobbles showing in borehole, interpreted as an andesite conglomerate or breccia.		60	70	10
Andesite:very hard, silicified, felsic groundmass, feldspars are anhedral, 1mm, white, some altered to clay, 3% pyrite, subhedral to anhedral, 1mm, white, some altered to clay, 3% pyrite, subhedral to anhedral, 1mm, disseminated throughout rock.		70	80	10
Andesite:pyrite is more disseminated through rock, very fine grained.		80	85	5
Andesite: very fine grained pyrite is fresh, medium				

8. WELL CONSTRUCTION  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started \_\_\_\_\_, 19\_\_\_\_  
 Date completed \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level: \_\_\_\_\_ feet below land surface  
 Artesian flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature: \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: Wayne Drilling Inc. Contractor  
 Address: P.O. Box 12370 Contractor  
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board: 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on site driller: 908

Signed: [Signature]  
 By driller performing actual drilling on site or contractor  
 Date: April 19, 1995

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

page 3 of 4 pages  
NOTICE OF INTENT NO. 14915

Consultant:

1. OWNER Kennedy/Jenks, Inc. ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 160 Hubbard Way, Suite #2 \_\_\_\_\_  
Reno, Nevada 89502 \_\_\_\_\_ Refuse, Inc

2. LOCATION 1/4 1/4 Sec. \_\_\_\_\_ T. \_\_\_\_\_ N/S R. \_\_\_\_\_ E. \_\_\_\_\_ County \_\_\_\_\_  
PERMIT NO. M/O-253 LL-2A 04-131-03 \_\_\_\_\_  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
brown siliceous rock fragments.		85	94	9
Andesite: increase in quartz (3%), white, anhedral in aphanitic groundmass, pyrite increases to 5% of rock.		94	115	21
Andesite: small rock fragments, harder (more siliceous), pyrite is irredescent and appears malleable-(chalcopyrite?) along fractures. Feldspar altered to clay.		115	125	10
Andesite: has aphanitic groundmass, pyrite is euhedral to anhedral.		125	130	5
Andesite: very fine rock fragments, increasing Quartz, pyrite is abundant along rock surfaces, (due to abundant fractures, veining).		130	145	15
Andesite: medium grained, aphanitic groundmass, 5-10% pyrite, disseminated throughout rock, is fine grained and anhedral.		145	160	15
Andesite:		160	170	10

8. WELL CONSTRUCTION  
Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
HOLE DIAMETER (BIT SIZE)  
From \_\_\_\_\_ To \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
Type perforation \_\_\_\_\_  
Size perforation \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level \_\_\_\_\_ feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Wayne Drilling Inc. Contractor  
Address P.O. Box 12370 Contractor  
Reno, Nevada 89510  
Nevada contractor's license number issued by the State Contractor's Board 22549  
Nevada driller's license number issued by the Division of Water Resources/the on-site driller 908  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date April 19, 1995

Date started \_\_\_\_\_, 19\_\_\_\_  
Date completed \_\_\_\_\_, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

OFFICE USE ONLY  
 Log No. 49974  
 Permit No. \_\_\_\_\_  
 Basin. 083  
 page 4 of 4 pages  
 NOTICE OF INTENT NO. 14915

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Consultant:

1. OWNER: Kennedy/Jenks, Inc. ADDRESS AT WELL LOCATION: \_\_\_\_\_  
 MAILING ADDRESS: 160 Hubbard Way, Suite #2  
Reno, Nevada 89502 Refuse, Inc

2. LOCATION: \_\_\_\_\_ 1/4 \_\_\_\_\_ 1/4 Sec. \_\_\_\_\_ T. \_\_\_\_\_ N/S R. \_\_\_\_\_ E. \_\_\_\_\_ County \_\_\_\_\_  
 PERMIT NO. M/O-253 LL-2A 04-131-03  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Andesite: medium grained, 5-10% pyrite, disseminated throughout rock is fine grained and anhedral.		170	178	8
Andesite Breccia:		178	185	7
Andesite:		185	201	16
Andesite: pyrite is less Disseminated, (possibly along fracture planes).		201	215	14
Andesite: pyrite is clustered, less disseminated, (possibly along fracture planes).		215	235	20
Andesite:		235	255	20
Andesite: feldspars are chloritized, less pyrite.		255	257	2
Andesite: no pyrite, feldspars are either fresh or chloritized, very small rock chips, minor pyrite, abundant feldspar which are white to chloritic.		257	278	21
Andesite: unaltered to propylitized, 40% phenocrysts in aphanitic groundmass, white to colorless, anhedral minor euhedral pyrite, epidote, groundmass has sucrosic.		278	282	4

8. WELL CONSTRUCTION  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started \_\_\_\_\_ 19 \_\_\_\_\_  
 Date completed \_\_\_\_\_ 19 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Bailer	Pump	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name: Wayne Drilling Inc. Contractor  
 Address: P.O. Box 12370 Contractor  
Reno, Nevada 89510  
 Nevada contractor's license number issued by the State Contractor's Board: 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 908  
 Signed Wayne Drilling Inc.  
 By driller performing actual drilling on site or contractor  
 Date: April 19, 1995