

REPORT NO. 95.29

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

49979  
PERMIT NO. 36270  
IN 085  
NOTICE OF INTENT NO. 28525

OWNER MB Construction  
MAILING ADDRESS 7055 Pah Rah Rd Sparks, Nv 89436

ADDRESS OF WELL Spring Ridge Subdivision  
Sparks, Nv 89436

2. WELL LOCATION NW 1/4 NE 1/4 SEC. 21 T 20N R 20 E Washoe COUNTY  
PERMIT NO. \_\_\_\_\_ PARCEL NO. 510-021-08 SUBDIVISION NAME Spring Ridge

3. TYPE OF WORK  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Refer to original log for #8 & #9				
5/16				
Weld on casing 6' below G.L. & backfill. Setup drill & drill out rock, dirt, PVC, wood & gravel to 200'. at 200' 6" liner encountered.				
Blow water until clear - approximately 70 GPM.				
Trip in tremie tube and pump neat cement.				
5/17/95				
Measure plug from top - 90' down. No water on top, pour well grout from top. Pull off casing to 6' below G.L.				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Depth Cased \_\_\_\_\_

HOLE DIAMETER (BIT SIZE)  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D.	Weight/Ft	Wall Thickness	From	To

PERFORATIONS:

Type Perforation \_\_\_\_\_ Size Perforation \_\_\_\_\_

From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

SURFACE SEAL:  Yes  No SEAL TYPE:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Seal Depth \_\_\_\_\_

PLACEMENT METHOD:  Pumped  Poured

GRAVEL PACKED:  Yes  No  
 From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

9. WATER LEVEL  
 Static Water Level 135 Feet Below Land Surface  
 Artesian Flow \_\_\_\_\_ GPM \_\_\_\_\_ PSI  
 Water Temperature \_\_\_\_\_ F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc  
 Address 625 Spice Islands Dr Ste L  
Sparks, Nv 89431

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1132  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Dated 5/18/95

Notes: Cement used - 10,152 lbs of neat cement.  
1.5 yards grout

Date Started 5/16/95 Date Completed 5/17/95

7. WELL TEST DATA

TEST METHOD	GPM	DRAWDOWN	TIME (HRS)
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			