

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Consultant: Western Energy Client: Western Energy NOTICE OF INTENT NO. 21858
 1. ~~OWNER~~ Steffen Robinson & Kirsten ADDRESS AT WELL LOCATION Winners Corner
 MAILING ADDRESS 1755 Plumb Lane #241 2191 Pyramid Way
Reno, Nevada 89502 Sparks, Nevada 89431
 2. LOCATION DDDA 1/4 1/4 Sec. 32 T. 20N N/S R. 20 E. Washoe County
 PERMIT NOM/O. 656 MW-3 027-342-06 Sparks Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other Tubex 190

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	3"	3"
Silty Gravels (GM), loose, non-plastic, brown, moist.		3"	2'	1' 11"
Clayey Sands (SC), stratified with sandy, gravelly layers, stiff, medium plasticity, brown to greenish, moist		2	11	9
Silty Gravels (GM), with abundant sand, very stiff, non-plastic, greenish brown, moist		11	19	8
Sandy Gravel, (GP), with cobbles, very stiff non-plastic, greenish brown, moist to very moist.		19	22	3
Sand (SP), with minor gravel, non-plastic, brown, wet to saturated.		22	26	4
Silty Clay (CL), stiff, medium to high plasticity, brown, saturated.		26	29.7	3.7

8. WELL CONSTRUCTION
 Depth Drilled 29.7 Feet Depth Cased 29.7 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 29.7 Feet
 9 5/16 Inches
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVC		Sch 40	0	29.7

End Cap & Locking Cap/ Locking Well Protector

Perforations:
 Type perforation Factory Sawn Slot
 Size perforation .020
 From 9 feet to 29.7 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 0-5
 Placement Method: Pumped Poured
 Bentonite Seal 5-7'
 Gravel Packed: Yes No Silica Sand #3
 From 7 feet to 29.7 feet

9. WATER LEVEL
 Static water level 20.8 feet below land surface
 Artesian flow n/a G.P.M. n/a P.S.I.
 Water temperature n/a °F Quality n/a

Date started June 7 1993
 Date completed June 7 1993

7. WELL TEST DATA

TEST METHOD	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
No test			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date January 4, 1994