

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29549

1. OWNER Don Sherman ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 2900 Whiskey Springs Road  
Reno, Nevada 89510  
 2. LOCATION NW 1/4 SE 1/4 Sec. 12 T. 22N N/S R. 21 E Washoe County  
 PERMIT NO. Area D 077-110-26 Parcel No. Palomino Valley Subdivision Name Out 1 12.2.1.3  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<b>DOMESTIC WELL ABANDONMENT:</b>				
Static water level @ <u>418 feet</u>				
Total Depth at <u>525 feet</u>				
Equipment used: <u>T4 W-1050 Drill with 2 man crew, support truck</u> <u>Down hole air operated perforator</u> <u>Cement pump &amp; mixer</u>				
Material used: <u>126 sacks of Portland Cement Type II</u> <u>0 sacks Bentonite</u>				
Method used: <u>Attempt to pull casing</u> <u>Perforate casing from 475 to 50 feet</u> <u>Evidence of exisiting cement seal between 50 &amp;</u> <u>Install tremie pipe, pump cement through pipe</u> <u>with 126 sacks, from bottom to surface.</u> <u>Fluid level to surface, let settle</u> <u>No cement makeup needed</u>				
Location: <u>In center of property on top of hill no fixed</u> <u>distances determined.</u>				
<u>Plugging of log 467φ5</u>				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

From \_\_\_\_\_ To \_\_\_\_\_

\_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5-23-95, 19\_\_\_\_  
 Date completed 5-26-95, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. Contractor  
 Address P.O. Box 12370 Contractor  
Reno, Nevada 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed Wayne Sherman  
 By driller performing actual drilling on site or contractor  
 Date June 1, 1995