

OFFICE USE ONLY
 Log No. 4999
 Permit No. _____
 Basin. 049

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29324

1. OWNER US BANK ADDRESS AT WELL LOCATION 801 LOAHO ST EIKO NV
 MAILING ADDRESS 801 LOAHO ST EIKO NV
 2. LOCATION SE 1/4 NE 1/4 Sec. 15 T. 34 N. R. 55 E EIKO County
 PERMIT NO. waiver MD 922 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CONCRETE		0	0.5	
Gray, Brown Clayey sand		0.5	4.5	
Gray Brown Sandy clay		4.5	7	
Brown sandy clay		7	11	
Brown silty clay		11	16	
Gray Brown SANDY gravel		16	19	
GRAY Brown sand		19	22.5	
Inter Bedded Grny		22.5	27	
Brown gravelly SAND and sandy gravel				
Brown sandy clay		27	32	
Brown Clayey sand		32	40	

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet
 HOLE DIAMETER (BIT SIZE)
 8" From 0 Feet To 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch 40	0	15

Perforations:
 Type perforation _____
 Size perforation .020
 From 15 feet to _____ feet
 From _____ feet to 40 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 0-13.5 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 13.5 feet to 40 feet

9. WATER LEVEL
 Static water level 32 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Drilling Inc Contractor
 Address 75 Lewers Creek Rd Carson City NV Contractor
 Nevada contractor's license number 13697A issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
 Signed John J. Lewis
 By driller performing actual drilling on site or contractor
 Date 5-17-95

Date started 4-8 1995
 Date completed 4-8 1995

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)