WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50001
Permit No.
Basin 270

NOTICE OF INTENT NO. 32883

1. OWNER Don Jones
MAILING ADDRESS P O Box 806 Winnemucca, NV 89446
ADDRESS AT WELL LOCATION 5790 Jungo Rd. Winnemucca, NV

2. LOCATION NW ¼ SW ¼ Sec. 26 T. 36 N/S R. 37 E. Humboldt County
PERMIT NO. (Issued by Water Resources) NOT ASSIGNED YET Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand w/some clay | | 0 | 15 | 15 |
| Clay | | 15 | 25 | 10 |
| Gravel | | 25 | 45 | 20 |
| Sandy Clay | | 45 | 70 | 25 |
| Multi colored shale | | 70 | 95 | 25 |
| Sand & Gravel | | 95 | 130 | 35 |

'95 MAY 22 P2:10 STATE ENGINEER

Date started May 2, 1995
Date completed May 3, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 40 | | 2 |

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 135 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | +2 | 90 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill Slot
Size perforation .125
From 90 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co Inc (Contractor)
Address P O Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed C. E. Epple (By driller performing actual drilling on site or contractor)
Date 5-18-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627