EW-6

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50006
Permit No.
Basin EE 061

NOTICE OF INTENT NO. 9570

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NW ¼ SE ¼ Sec. 19 T. 36 N/S R. 50 E. EUREKA County
PERMIT NO. 55140 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DISPLACED A BENTONITE SLURRY | | | | |
| WITH A 70 SECOND FUNNEL | | | | |
| VISCOSITY FROM 50 FEET TO 650 FEET. | | | | |
| PLACED A 16 LB/GAL CEMENT PLUG | | | | |
| FROM SURFACE TO 50 FEET. | | | | |

Date started MAY 30, 1995
Date completed MAY 31, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 650 Feet Depth Cased 650 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 30 | Inches | 0 | Feet | 78 | Feet |
| 17-1/2 | Inches | 78 | Feet | 650 | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 24 | 63.41 | .250 | 0 | 78 |
| 12 | 33.38 | .250 | +2 | 130 |
| 12 | 33.38 | .250 | 170 | 210 |
| 12 | 33.38 | .250 | 250 | 290 |
| 12 | 33.38 | .250 | 330 | 370 |

Perforations:
Type perforation LOUVERED
Size perforation ROSCOE MOSS FUL-FLO
From 130 feet to 170 feet
From 210 feet to 250 feet
From 290 feet to 330 feet
From 370 feet to 650 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 650 feet

9. WATER LEVEL
Static water level 201 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1808

Signed SCOTT ACKLEY Scott Ackley
By driller performing actual drilling on site or contractor

Date JUNE 15, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627