

WHITE—DIVISION OF WATER RESOURCES
 CANARY—CLIENT'S COPY
 PINK—WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 50609
 Permit No. _____
 Basin. 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26415

1. OWNER BARRICK GOLDSTRIKE ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE
 MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

2. LOCATION SW 1/4 NW 1/4 Sec. 19 T. 36 S. R. 50 E. EUREKA County
 PERMIT NO. M/O-44 1A Parcel No. N/A Subdivision Name N/A
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DISPLACED 15 LB/GAL CEMENT				
SLURRY FROM 805 FT TO SURFACE				
IN DEEP COMPLETION,				
AND FROM 278 FT TO SURFACE				
IN SHALLOW COMPLETION				

8. WELL CONSTRUCTION
 Depth Drilled 840 Feet Depth Cased 805 Feet

HOLE DIAMETER (BIT SIZE)

From	To
12 1/4 Inches	0 Feet 79 Feet
6 1/4 Inches	79 Feet 840 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	28	.275	0	79
1 1/4	2	SCH 40	0	238
1 1/4	2	SCH 40	278	765

Perforations:
 Type perforation DRILLED HOLES
 Size perforation .125
 From 238 feet to 278 feet
 From 765 feet to 805 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 106 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 106 feet to 840 feet

9. WATER LEVEL
 Static water level 218 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 84 °F Quality _____

Date started MAY 19 19 95
 Date completed MAY 19 19 95

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING
 Contractor
 Address 2286 WEST 1500 SOUTH
 Contractor
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1808

Signed SCOTT ACKLEY *Scott Ackley*
 By driller performing actual drilling on site or contractor
 Date MAY 29, 1995