WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

EW-18
STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50010
Permit No.
Basin 061

NOTICE OF INTENT NO. 29254

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ NW ¼ Sec. 19 T. 36 ☒N/S R. 50 E. EUREKA County
PERMIT NO. 55141 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BEDROCK, BROWN,		725		
WHITE & TAN			830	105
BLACK & GRAY ROCK		830		
SOME CLAY			1030	200
BROWN ROCK, SOME		1030		
CLAY			1070	40
BLACK & GRAY ROCK		1070	1170	100
BLACK ROCK, SOME CLAY		1170	1510	340

Date started MAY 2, 19 95
Date completed MAY 11, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1510 Feet Depth Cased 1510 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
31 Inches	0 Feet	46 Feet
17 1/2 Inches	46 Feet	725 Feet
12 Inches	725 Feet	1510 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	63.41	.250	0	46
12	29.31	.250	0	120
8	22.36	.250	685	725

Perforations:
Type perforation LOUVERED
Size perforation 1/8"
From 12" 120 feet to 721 feet
From 8" 725 feet to 1510 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 725 feet

9. WATER LEVEL
Static water level 740 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 100 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1796
Signed RON BEHREANDT Ron Behreandt
By driller performing actual drilling on site or contractor
Date MAY 17, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627