WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52011
Permit No.
Basin 177

NOTICE OF INTENT NO. 24903

1. OWNER Steve Sethard
MAILING ADDRESS Clover Valley
Wells, Nevada 89836
ADDRESS AT WELL LOCATION Same
Lot 1

2. LOCATION NW ¼ NE ¼ Sec. 18 T. 36 N/S R. 62 E. 31/50 County
PERMIT NO. 60363 (Issued by Water Resources) 08-330-08-6 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	3	
Coarse Gravel		3	32	
Red Shale with		32	72	
Fine Gravel	X		72	
Soft Red Clay		72	85	
Yellow Clay & Gravel	X	85	100	
Yellow Shale Hard	X	100	115	
Bright Yellow shale	X	115	145	
25 GS 15412	Goulds			
Set on 126'	T & C			

Date started 6-14- 1995
Date completed 6-19- 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Pumped	20	80	12

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches		0 Feet	60 Feet
7 7/8 Inches		60 Feet	145 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.42	.188	+2	145

Perforations:
Type perforation Holte Downhole
Size perforation 2" x 1/8"
From 85 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60 +
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow 0 G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name R. Reynolds (Contractor)
Address Wells, Nevada (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 014410
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1390
Signed (By driller performing actual drilling on site or contractor)
Date 6-20-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627