WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50014
Permit No.
Basin 069

NOTICE OF INTENT NO.

1. OWNER Diamond Plastics
MAILING ADDRESS P O Box 189
Golconda, NV 89414

ADDRESS AT WELL LOCATION Diamond Plastics
Plant - 1 mile NW of Golconda

2. LOCATION ~~SE~~ NE ¼ ~~SE~~ NE ¼ Sec. ~~20~~ 29 T. ~~39~~ 36 (N)/S R. 40 E. Humboldt County
PERMIT NO. 60423 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Compacted Gravel		0	1	1
Clay w/Gravel		1	18	17
Sand-Gravel-Cobbles		18	24	6
Fractured Rock		24	32	8
Sand & Gravel		32	38	6
Fractured rock w/sand		38	65	27
Fractured rock w/clay		65	80	15
Sand & Gravel		80	92	12
Clay		92	106	14
Clay w/sand layers		106	195	89
Clay w/rock		195	210	15

'95 MAY 22 P2:10
STATE ENGINEER

Date started May 10, 1995
Date completed May 12, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		3 hrs.

8. WELL CONSTRUCTION
Depth Drilled 210 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	210 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	120

Perforations:
Type perforation Double Mill Slot
Size perforation .125
From 120 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 24 ft feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Norm °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling& Pump Co Inc.
Contractor
Address P O Box 590
Contractor
Winnemucca, NV 89446

Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed C. C. Epler
By driller performing actual drilling on site or contractor
Date 5-18-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627