OB-2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50017
Permit No.
Basin 066

NOTICE OF INTENT NO. 28766

1. OWNER FIRSTMISS GOLD INC.
MAILING ADDRESS P.O. BOX 220
GOLCONDA, NV 89414

ADDRESS AT WELL LOCATION
FIRSTMISS - GETCHELL MINE SITE

2. LOCATION NW ¼ NE ¼ Sec. 33 T. 39 (N) S R. 42 E. HUMBOLDT County

PERMIT NO. W-428 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL, FILL, SAND		0	15	15
BASALT	120 GPM	15	1195	1180
SHALE, SANDSTONE		1195	1540	345
SKARN, CLAYS		1540	1800	260
CLAYS		1800	1900	100
SHALE		1900	2310	410

Date started MAY 15, 1995
Date completed MAY 30, 1995

7. WELL TEST DATA

TEST METHOD: [X] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIRLIFT			
DEEP COMP.	12		5-1/2
SHALLOW COMP	8		6
BAIL			
DEEP COMP.	1-1/2		4
SHALLOW COMP	2		3-1/2

8. WELL CONSTRUCTION
Depth Drilled 2310 Feet Depth Cased 2300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
17-1/2 Inches		0 Feet	28 Feet
10 Inches		28 Feet	795 Feet
9-7/8 Inches		795 Feet	2310 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	28.04	1/4	0+2	28
2-1/4	3.65	1/8	+2	1500
2-1/4	3.65	1/8	+2	1900

Perforations:
Type perforation SLOT
Size perforation .125 INCHES
From 1900 feet to 2300 feet
From 1500 feet to 1800 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 69 FEET
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 1874, 1458 feet to 2310, 1820 feet

9. WATER LEVEL
Static water level 262(SHALLOW) 492-DEEP feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 73°F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1773

Signed MARK WAITE *Mark Waite*
By driller performing actual drilling on site or contractor

Date MAY 30, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627