WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
m/o 40435-1

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50020
Permit No.
Basin 067

NOTICE OF INTENT NO. 28553

1. OWNER SANTA FE PACIFIC GOLD
MAILING ADDRESS ~~WEST~~ 861 West 6th ST.
WINN. NV. 89446.
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SW ¼ Sec. 5 T 40 N S R 43 E HUMBOLDT County
PERMIT NO. m/o 918 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ALLUVIUM | | 0 | 120 | 120 |
| CLAY SAND | X | 120 | 170 | 50' |
| GRAVEL | | | | |
| CSSI 8-20 | | 170 | 115 | 55 |
| BENTONITE 3/8" PELLETTS | | 115 | 113 | 2 |
| ABANTO NITE SLURRY | | 113 | 55 | 58 |
| ENVIRO COURSE | | 55 | 50 | 5 |
| CEMENT | | 0 | 50 | 50 |

Date started 5-31, 1995
Date completed 5-31, 1995

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 10 | 10' | 1 |

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 5 5/8 Inches | | 0 Feet | 170 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 1½ | SCH 80 | PVC | 0 | 120 |

Perforations:
Type perforation SLOT 1.5" SCH 80 PVC
Size perforation .020
From 120 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 115 feet to 170 feet

9. WATER LEVEL
Static water level 102.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EKLUND DRILLING (Contractor)
Address P.O BX 2786 (Contractor)
ELKO NV.
Nevada contractor's license number 0030823
issued by the State Contractor's Board 0019378
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1788
Signed Joe Weld (By driller performing actual drilling on site or contractor)
Date 5-31-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627