WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50232
Permit No.
Basin 95

NOTICE OF INTENT NO. 22911

1. OWNER Tom & Kathy Rice
MAILING ADDRESS 255 Nicole Drive
Sparks, Nevada 89436
ADDRESS AT WELL LOCATION 625 Calle De La Plata Sparks

2. LOCATION SW ¼ SW ¼ Sec. 17 T. 21 N/S R. 21 E. Washoe County
PERMIT NO. 005272 (Issued by Water Resources) 076-310-22 (Parcel No.) Spanish Springs Valley Ranches (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0'	10'	
Granite		10'	170'	
Clay		170'	180'	
Granite		180'	305'	
Colar Red		305'	320'	
Fracture		330'	340'	
Granite		340'	385'	
Granite (soft)		385'	425'	
Hard Granite		425'	530'	
Coarse sand + H20		530'		
small amount			665'	
Gravel + H20		665'	745'	239'

Date started 7/26, 19 95
Date completed 8/20, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	12	725'	5 Hours

8. WELL CONSTRUCTION
Depth Drilled 745' Feet Depth Cased 745' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼	Inches	0	Feet	20	Feet
9 7/8	Inches	20	Feet	55	Feet
8 ½	Inches	55	Feet	745	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	14	188	+ 2	745'

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 3
From 499 feet to 745 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50' +
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 745 feet

9. WATER LEVEL
Static water level 574' feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature 57 °F Quality fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Miller & Sons Drilling (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, Nevada 89507
Nevada contractor's license number issued by the State Contractor's Board 37915
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1743
Signed (By driller performing actual drilling on site or contractor)
Date 8-31-95

Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627