

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT #28871

1. OWNER Dorothy Moyle ADDRESS AT WELL LOCATION 20 miles N.E. of
 MAILING ADDRESS Box 24 Eureka, NV on 16th Street
Eureka, NV 89316

2. LOCATION NE 1/4 NE 1/4 Sec. 19 T. 22 N&R. 54 E Eureka County
 PERMIT NO. Lots 1,2,3 & 4 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	4	4
Course Sand		4	20	16
Black Clay		20	50	30
Water Sand & Black Clay	x	50	55	5
Sandy Black Clay		55	90	35
Water Sand & Black Clay	x	90	95	5
Sandy Black Clay		95	105	10
Sandy Grey Clay & Course	x	105	180	75
Water Sand				

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	180

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 rows
 From 100 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 180 feet

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started September 5, 1995
 Date completed September 8, 1995

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
75	85	2	

Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue
Ely, Nv 89301 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
 Signed Arnold D. Christiansen
 By driller performing actual drilling on site or contractor
 Date October 16, 1995