

OFFICE USE ONLY
 Log No. 50035
 Permit No. _____
 Basin 153

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTEREST NO. 28874
4 miles north of

1. OWNER Ernie Allen
 MAILING ADDRESS P.O. Box 121
Eureka, NV 89316
 ADDRESS AT WELL LOCATION Eureka on Highway 278

2. LOCATION SE 1/4 NE 1/4 Sec. 28 T 20 N R 53 E Eureka County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____
 APN 07-370-08

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Sand & Gravel		5	25	20
Calitche		25	45	20
Cemented Gravel & Boulders		45	95	50
Gravel & Clay		95	105	10
Gravel		105	110	5
Cemented Gravel & Clay		110	140	30
Gravel & Clay	x	140	150	10
Cemented Gravel & Clay		150	180	30
Course Water Sand	x	180	190	10
Cemented Gravel & Clay		190	200	10
Cemented Gravel & Boulders		200	210	10
Cemented Gravel & Clay		210	245	35
Course Water Sand	x	245	250	5
Cemented Gravel & Clay		250	260	10
Course Water Sand	x	260	265	5
Cemented Gravel & Clay		265	280	15

8. WELL CONSTRUCTION
 Depth Drilled 280 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 200 Feet
6 1/8 Inches 200 Feet 280 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	200
5 1/2	14.62	.258	190	270

Perforations: Factory 6 5/8" = 1/8" x 2 1/2" 6 rows
Type perforation Torch 5 1/2" = 1/8" x 5" 5 rows
 Size perforation _____
 From 140 feet to 270 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 198 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started September 18, 1995
 Date completed September 23, 1995

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	45	72	1

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
 Address 557 Ely Avenue
Ely, NV 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
 Signed Jerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date October 16, 1995