

OFFICE USE ONLY  
 Log No. 50036  
 Permit No. \_\_\_\_\_  
 Basin. 085

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30619

1. OWNER RAY & DIANA ROBISON ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 510 Gault Way 320 Campo Rico Crt.  
Sparks, Nevada 89431 Sparks, Nevada  
 2. LOCATION NW 1/4 SE 1/4 Sec. 1 T. 21N N/S R. 20 E Washoe County  
 PERMIT NO. 076-281-20 Spanish Springs  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Yellow volcanic rock		1	17	16
Light yellow volcanic rock		17	48	31
Gray volcanic rock		48	55	7
Light yellow volcanic rock		55	105	50
Soft rusty yellow clay		105	120	15
Light yellow volcanic rock		120	145	25
Light yellow with gray mix volcanic rock		145	243	98
Cream white volcanic rock		243	268	25
Black volcanic rock		268	278	18
Fracture (NO WATER)		278	279	1
Black-gray volcanic rock		279	321	42
Fracture (app 3 GPM)	X	321	322	1
Black & gray volcanic rock		322	342	20
Fracture (app 2 GPM)	X	342	343	1
Black volcanic rock		343	361	18
Fracture rock	X	361	391	30
Black volcanic rock		391	400	9

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 400 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	400

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 355 feet to 395 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 400 feet

9. WATER LEVEL  
 Static water level 274 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 21 P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, me on site driller 923  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date October 23, 1995

Date started 10-18-95, 19\_\_\_\_  
 Date completed 10-20-95, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>21</u>			