WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

14DC

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50641
Permit No. 0-
Basin 0

NOTICE OF INTENT NO. 38569

1. OWNER PATRICK & KATHY McPARTLAND
MAILING ADDRESS 17735 Fantail
Reno, Nevada 89506

ADDRESS AT WELL LOCATION 2056 Antelope Valley Road
Reno, NV 89506

2. LOCATION SW ¼ SE ¼ Sec. 14 T 22N N/S R 19 E Washoe County
PERMIT NO. Issued by Water Resources — 079-480-64-74 Parcel No. — Antelope VAlley Ranchos Est. Subdivision Name #1995 par 2

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown sandy clay		2	16	14
Brown weathered granite sands		16	18	2
Brown sandy clay		18	46	28
Brown clay		46	86	40
Rusty weathered granite		86	99	13
Gray granite		99	153	54
Fracture(app 3GPM)	X	153	154	1
Gray granite		154	195	41
Fracture(app 3GPM)	X	195	205	10
Fracture granite	X	205	215	10
Gray hard granite		215	225	10

Date started 9-25-95, 19
Date completed 9-26-95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
26		

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	225 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	225

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 176 feet to 216 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 225 feet

9. WATER LEVEL
Static water level 86 feet below land surface
Artesian flow G.P.M. 26 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. Contractor
Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Gary C. Hedman
By driller performing actual drilling on site or contractor
Date September 28, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627