WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK
Well No. 2#

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 80042
Permit No.
Basin 076

NOTICE OF INTENT NO. 32656

1. OWNER GARY WOLRATH
MAILING ADDRESS 105 Apple Court Fernley NV
ADDRESS AT WELL LOCATION 105 Apple Court Fernley NV

2. LOCATION S ¼ SW ¼ Sec. 10 T. 20 N/S R 24 E Lyon County
PERMIT NO. ____ Issued by Water Resources | 21-051-28 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	16	16
Sand, Clay		16	46	30
Clay		46	74	28
Gravels		74	92	18
Boulder, Gravels		92	115	23
Bedrock	145	115	215	100'
Water in fractures	215			

RECEIVED
95 SEP 15 A 11:35
STATE ENGINEERS OFFICE

Date started 8/21/95, 19
Date completed 8/24/95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50-55	2½ hrs	

8. WELL CONSTRUCTION
Depth Drilled 215 Feet Depth Cased 216' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	115' Feet
8 3/4 Inches	115 Feet	215' Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.	1.88	+1	215

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 6" x 3# rows perf
From 110' feet to 120' feet
From 195 feet to 215 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70+
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70' feet to 216' feet

9. WATER LEVEL
Static water level 64' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 0 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Green Drilling Inc
Contractor
Address PO. 599
Contractor
SS NV 89428

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876

Signed [signature]
By driller performing actual drilling on site or contractor

Date 9/5/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

I