WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK
Well No. 1#

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 50043
Permit No.
Basin 070

NOTICE OF INTENT NO. 32655

1. OWNER Jim Foster
MAILING ADDRESS 155 Apple Court
Fernley Nevada

ADDRESS AT WELL LOCATION 155 Apple Court
Fernley NV

2. LOCATION S ¼ SW ¼ Sec. 10 T. 20 N/S R. 24 E. Lyon County
PERMIT NO. _____ Issued by Water Resources | 21-051-29 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 8 | 8 |
| Sand, Clay | | 8 | 19 | 11 |
| Clay | | 19 | 35 | 16 |
| Gravels | | 35 | 60 | 25 |
| Boulders, Gravels | 1 | 60 | 84 | 24 |
| Bedrock, Fractured | 160 | 84 | 220 | 136 |
| Water in fractures | 220 | | | |

RECEIVED
95 SEP 15 AM 11:35
STATE ENGINEERS OFFICE

Date started 8/15/95, 19
Date completed 8/18/95, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 40-45 | 3hrs | |

8. WELL CONSTRUCTION
Depth Drilled 220' Feet Depth Cased 221' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 1 Feet | 75' Feet |
| 8 3/4 Inches | 75 Feet | 220' Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | 1.88 | +1 | 220 |

Perforations:
Type perforation Torch Cut
Size perforation 3/16 x 6 x 3# Rows Perf
From 100' feet to 115' feet
From 200' feet to 220' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 75'
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 75 feet to 220' feet

9. WATER LEVEL
Static water level 59' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality ✓ Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Green Drilling Inc
Contractor
Address PO 599
Contractor
SS NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876

Signed [signature]
By driller performing actual drilling on site or contractor

Date 9/4/95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627